Mistlebrook Vale School (sample)
13 Windlestraw Road, Mistlebrook Vale, Northland (sample address)
Supply ID SAMPLE001
Moana Whitlock - 09 000 0102
principal@mistlebrookvale.example

Lab sample report

Mistlebrook Vale School (sample)

13 Windlestraw Road, Mistlebrook Vale, Northland (sample address)

Samples taken 2025-11-01 to 2026-11-05 (Pacific/Auckland)

7 / 4	0	1	1	2026-12-04
Samples taken / samples due	Late or missed due dates	E. coli detections	Total coliform detections	Next sample due by

"Due" is the least the schedule asked for in the period; "late or missed" counts each due date that passed with no sample. The next sample is as at 2026-11-05 15:00 NZDT.

1 sample in the period is still awaiting results.

THE SAMPLING RULE THAT APPLIES

As the site's lab settings in WYLA state it. The strictest schedule that applies decides.

Schedule	How often	Where it comes from
Ministry of Education: every calendar month, school holidays included	a sample in every calendar month	Ministry of Education requirement for state schools (Taumata Arowai schools page, "Required by the Ministry of Education": "Test for E. coli and total coliforms every month, including during the school holidays"; NZSPA guidance: every month, including during the school holidays); results reported in the "water testing results" tab of the Argest portal, re-test results included (NZSPA)
Acceptable Solution, 101 people or more: monthly	every 1 month, counted from the last sample	Self-supplied Buildings Acceptable Solution 2025 SSB.13(c)(ii): "monthly if the population is 101 or more"

State school	yes
Population served	168
Schedule started	2026-07-20 09:00 NZST
After a positive	3 clear tests in a row. Ministry of Education requirement for state schools (Taumata Arowai schools page): "Three clear tests are required after a positive test"; NZSPA: "do 3 consecutive re-tests"

MONTH BY MONTH

One box per calendar month at the site; the number is the samples taken in it.

Nov 2025	Dec	Jan 2026	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov
-	-	-	-	-	-	-	-	1	1	1	3	1

sampled and clear · a positive result · late or missed · not due · sampled, result awaited or "ask the lab"

STANDING AFTER A POSITIVE RESULT

As at 2026-11-05 15:00 NZDT, over every sample on the register.

E. coli detected in the sample taken 2026-10-08 09:20 NZDT (sample NAL-261008-01). Three clear tests are needed: 2 of 3 so far. Treat the water as unsafe until then: stop drinking and food use, put up do-not-drink notices, and notify Taumata Arowai and the Ministry of Education.

EVERY SAMPLE IN THE PERIOD

Oldest first, at the site's local time. A positive result is in red.

Taken (local)	Sample ID	Sampling point	Laboratory	Taken by	E. coli	Total coliforms	Other results	Outcome
2026-07-23 10:15 NZST	NAL-260723-01	Staffroom kitchen tap	Northfield Analytical Laboratory (sample)	Caretaker	<1 MPN/100 mL	<1 MPN/100 mL	-	Clear

(c) 2026 Cutting Edge Integration. All rights reserved.

Taken (local)	Sample ID	Sampling point	Laboratory	Taken by	E. coli	Total coliforms	Other results	Outcome
2026-08-15 09:30 NZST	NAL-260815-01	Staffroom kitchen tap	Northfield Analytical Laboratory (sample)	Caretaker	<1 MPN/100 mL	<1 MPN/100 mL	-	Clear
2026-09-11 09:35 NZST	NAL-260911-01	Staffroom kitchen tap	Northfield Analytical Laboratory (sample)	Caretaker	<1 MPN/100 mL	<1 MPN/100 mL	-	Clear
2026-10-08 09:20 NZDT	NAL-261008-01	Staffroom kitchen tap	Northfield Analytical Laboratory (sample)	Caretaker	**3 MPN/100 mL (detected)**	**12 MPN/100 mL (detected)**	-	**POSITIVE**
2026-10-12 08:40 NZDT	NAL-261012-01	Staffroom kitchen tap	Northfield Analytical Laboratory (sample)	Caretaker	<1 MPN/100 mL	<1 MPN/100 mL	-	Clear
2026-10-15 08:45 NZDT	NAL-261015-01	Staffroom kitchen tap	Northfield Analytical Laboratory (sample)	Caretaker	<1 MPN/100 mL	<1 MPN/100 mL	-	Clear
2026-11-04 08:50 NZDT	NAL-261104-01	Staffroom kitchen tap	Northfield Analytical Laboratory (sample)	Caretaker	awaited	awaited	-	Results awaited

6 earlier versions of these entries were corrected later and are not listed; the register (CSV) keeps every version.

PEOPLE AND ORGANISATIONS

Role	Name	Organisation	Phone	Email
Principal	Moana Whitlock	Mistlebrook Vale School (sample)	09 000 0102	principal@mistlebrookvale.example
Board contact	Graham Tolley	Board of Trustees	09 000 0103	board@mistlebrookvale.example
Caretaker / property manager	Bill Sorrell	Mistlebrook Vale School (sample)	09 000 0104	caretaker@mistlebrookvale.example
Project manager	Hana Ruddock	Te Raki Rural Schools Water Programme (sample)	09 000 0101	hana.ruddock@teraki-water.example
Installer	Pita Hargreave	Northern Tank and Pump (sample)	09 000 0105	install@northerntankpump.example
Service company	Sione Maddock	Clearflow Water Services (sample)	09 000 0106	service@clearflowwater.example
Inspector	Karen Ashby	Drinking water assessor (sample)	09 000 0107	k.ashby@waterassessor.example
Laboratory	Results desk	Northfield Analytical Laboratory (sample)	09 000 0108	results@northfieldlab.example

(c) 2026 Cutting Edge Integration. All rights reserved.